

CERTIFICATE OF COMPLIANCE

Certificate Number E502837
Report Reference E502837-20190326
Date 2023-December-06

Issued to: SOLAR STACK INC
1071 SW 30th Ave
Deerfield Beach FL, 33442 US

This is to certify that representative samples of MOUNTING SYSTEMS, MOUNTING DEVICES, CLAMPING DEVICES AND GROUND LUGS FOR USE WITH PHOTOVOLTAIC MODULES AND PANELS
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 2703, Mounting Systems, Mounting Devices, Clamping/Retention Devices, And Ground Lugs for use with Flat-Plate Photovoltaic Modules and Panels

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E502837
Report Reference E502837-20190326
Date 2023-December-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Ridged Systems LLC mounting system model Solar Stack.



Deborah Jennings-Conner
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

<u>Models</u>	<u>Section</u>	<u>Report Date</u>
USL/CNL - Ridged Systems LLC mounting system model Solar Stack	1	2019-03-26

DESCRIPTION

PRODUCT COVERED:

USL/**CNL** - Ridged Systems LLC mounting system model Solar Stack.

GENERAL:

*USL/**CNL** - Indicates products were investigated in accordance with the Standard for Rack Mounting Systems, Mounting Devices, Clamping/Retention Devices and Ground Lugs for Use with Flat-Plate Photovoltaic Modules and Panels, UL/ANSI 2703, 1st Edition, dated January 28, 2015.

The system and components described in this Report are used to create a mounting system for Photovoltaic Modules that employ aluminum mounting frames.

The system has been evaluated for the creation of an equipotential bond for the interconnected module frames, which can then be grounded in accordance to the U.S. National Electrical Code (U.S. NEC).

The system employs top-down clamps which have been evaluated for frame-to-system bonding, at a mounting torque and with specific modules defined by the Applicant. The system has been assessed to a maximum Over-Current Device (OCD) Protection level of 20 Amps.

This system has been evaluated for bonding per the requirements of UL 2703 1st Edition.